

At Your Service

Groton Utilities WTP Lab 295 Meridian St. Groton, CT 06340 (860) 446-4082 Stephen Dietrich, Lab Director CT Lab Registration # PH-0409

Groton Public Schools, 1st draw Lead and Copper testing

Schools: Fitch High School

FIELDHOUSE
Action Level > 0.015 1.30

	Action Level >	0.015	1.30
Locations	Date of sampling	Lead	Copper
FHS 30A	3/1/19	ND<0.0010	0.024
FHS 30B	3/1/19	ND<0.0010	0.021
FHS 30C	3/1/19	0.0012	0.015
	•		
<u> </u>			

All results in m	<u>g/L</u>	
		= lead result greater than 0.015 mg/L
All lead and cop	per analyses performed by	our subcontract lab, CT DPH registration # PH-0116.
Collected by:	JR	
Stephen	- Dietrich	

Stephen Dietrich?โลโซป์เรียงใ

Groton, Connecticut 06340 T 860-446-4900 F 860-446-4998