

At Your Service

Groton Utilities WTP Lab 295 Meridian St. Groton, CT 06340 (860) 446-4082 Stephen Dietrich, Lab Director CT Lab Registration # PH-0409

Groton Public Schools, 1st draw Lead and Copper testing

Schools: Fitch High School, Claude Chester

	Action Level >	0.015	1.30
Locations	Date of sampling	Lead	Copper
FHS 8	1/26/19	ND<0.0010	0.039
FHS 35	1/26/19	ND<0.0010	0.022
CC 17	1/26/19	ND<0.0010	0.110
FOUNTAIN			
		+***	

All results in mg/L
= lead result greater than 0.015 mg/L All lead and copper analyses performed by our subcontract lab, CT DPH registration # PH-0116.
Collected by: JR
Stephen Dietrich, Lab Director